

BOARD OF
SUPERVISORS

THOMAS D. HARVEY
North District

ERNIE Q. REED
Central District

JESSE N. RUTHERFORD
East District

J. DAVID PARR
West District

DR. JESSICA LIGON
South District



CANDICE W. MCGARRY
County Administrator

AMANDA B. SPIVEY
Administrative Assistant/
Deputy Clerk

GRACE E. MAWYER
Director of Finance and
Human Resources

ADDENDUM #1

Date: October 3, 2025

Re: Generator Replacement – Fire/EMS Stations

To: Bidders

Bid Date: **Remains Unchanged – Bids due October 17, 2025 at 2:00 PM EDT.**

From: Nelson County

Contact: Grace Mawyer

Important Note: As an alternative, bids may be submitted through the eVA site for this Bid. If submitting an electronic response in eVA, please ensure that it is submitted to the latest version of the solicitation based on this Addendum 1. Bidders bear all responsibility for properly submitting their bids. If submitting bids electronically via eVA, bidders should ensure they understand the platform and its operating requirements. eVA provides assistance, but bidders should prepare in advance of the bid time and provide adequate time for training and/or technical assistance, if required, to ensure their bids are properly registered on the eVA site. Nelson County will not be able to assist a bidder in placing their bid on the eVA site. Bids received through the eVA site will be opened and read aloud at the Bid Opening. There will not be a virtual bid opening. Results of the Bid will be published on eVA.

Addendum #1 provides the following modifications and additions to the Scope of Work for the above referenced project and clarifications to questions received to date. Bidders are instructed to include the additional cost of work in their Bid for the project:

- 1) Nelson County received an inquiry concerning feeder upgrades. Due to the upgrade from 15kw to 80kw at the Lovington Volunteer Fire Department location, the contractor will be responsible for the feeder line upgrade.
- 2) Nelson County received an inquiry concerning commissioning. Before final project sign-off, the contractor must complete a commissioning/start-up checklist that has been approved by the manufacturer.

END OF ADDENDUM #1